

_IP R	PIPE SUPPORT SCHEDULE	
	PIPE SIZE	MAX. SPACING
	3/4"	4'
DUCT	1"	6'
VING IONS.	1 1/4"	6'
	1 1/2"	6'
	2"	6'
	2 1/2"	8'
ING	3"	8'
≣ } H	4"	8'
OF	NOTES: 1. PIPING SHALL BE SUPPORTED AT ALL ELBOWS AND TEES, AND SHALL BE SPACED AS SPECIFIED IN TABLE.	
	2. PIPING SHALL BE SLOPED AND ROUTED TO PREVENT TRAPPING CONDENSATE (EXCEPT AT DIRT LEGS) AND TO FACILITATE CONDENSATE DRAINAGE.	
ł	VERSABLOCK 24860 BOISE RIVER ROAD PARMA, ID 83660 866.612.5625 blockinfo@versablock.com	