2. All pressurized non-storage type water heaters shall be provided with a pressure relief valve installed at the hot water outlet with no shut off valve between the heater and the relief valve.

3. Temperature and pressure relief valves shall be installed so that the sensing element of the valve extends into the heater or tank and monitors the temperature in the top 6" of the heater or tank.

4. A vacuum relief valve shall be installed in each water heater and hot water storage tank which, when measured from the bottom of the heater or tank, is located more than 20 feet above any faucet or outlet served by the heater or tank.

5. Every relief valve which is designed to discharge water or steam shall be connected to a discharge pipe.

a. The discharge pipe and fittings shall be made of a material acceptable for water distribution piping in accordance with s. SPS 384.30 (4) (e) 1.

b. The discharge pipe and fittings shall have a diameter not less than the diameter of the relief valve outlet.

c. The discharge pipe may not be trapped.

d. No valve may be installed in the discharge pipe.

e. The discharge pipe shall be installed to drain by gravity flow to a floor served by a floor drain or to a receptor in accordance with s. SPS 382.33 (8). The outlet of the discharge pipe shall terminate within 6" over the floor or receptor, but not less than a distance equal to twice the diameter of the outlet pipe. The outlet of the discharge pipe may not be threaded.

f. The discharge pipe for a water heater shall terminate within the same room or enclosure within which the water heater or hot water storage tank is located.

(e) Controls. 1. All hot water supply systems shall be equipped with automatic temperature controls capable of adjustments from the lowest to the highest acceptable temperature settings for the intended use.

2. A separate means shall be provided to terminate the energy supplied to each water heater and each hot water circulation system.

(6) LOAD FACTORS FOR WATER SUPPLY SYSTEMS. (a) Intermittent flow fixtures. The load factor for intermittent flow fixtures on water supply piping shall be computed in terms of water supply fixture units as specified in Tables 382.40-1b and 382.40-2 for the corresponding fixture and use. Water supply fixture units may be converted to gallons per minute in accordance with Table 382.40–3 or 382.40–3e.

(b) Continuous flow devices. The load factor for equipment which demands a continuous flow of water shall be computed on the basis of anticipated flow rate in terms of gallons per minute.

<b>Distribution and Service</b>									
Supply	Tag and Band Color	Tag Shape	Tag Size	Tag Legend <sup>a</sup>					
Potable	Green	Round	3" diam- eter	Safe Water					
Nonpotable	Yellow	Triangle	4″ sides	Nonpotable Water or Not Safe for Drinking					
Reuse (Nonpotable)	Purple	Triangle	4″ sides	Nonpotable Water or Not Safe for Drinking or Specific Use <sup>b</sup>					
Device Specific <sup>c</sup>	Gray	Triangle	4" sides	Specific Use <sup>b</sup>					

Table 382.40–1a

<sup>a</sup> All nonpotable water outlets shall be identified at the point of use for each outlet with the following legends or as otherwise approved by the department.

<sup>b</sup> Tag should reflect the intended use. c Serving an individual or similar plumbing fixtures or appliances.

Table 382.40–1b Water Supply Fixture Units for Nonpublic Use Fixtures

Type of Fixture <sup>a</sup>	Water Supply Fixture Units (wsfu)			
	Hot	Cold	Total	
Automatic Clothes Washer	1.0	1.0	1.5	
Bar Sink		0.5	1.0	
Bathtub, with or without Shower Head		1.5	2.0	
Bidet		1.0	1.5	
Dishwashing Machine			1.0	
Glass Filler		0.5	0.5	
Hose Bibb:				
1/2'' diameter		3.0	3.0	
3/4'' diameter		4.0	4.0	
Kitchen Sink	1.0	1.0	1.5	
Laundry Tray, 1 or 2 Compartment		1.0	1.5	
Lavatory		0.5	1.0	
Manufactured Home		15	15	
Shower, Per Head	1.0	1.0	1.5	
Water Closet, Flushometer Type		6.0	6.0	
Water Closet, Gravity Type Flush Tank		2.0	2.0	
Bathroom Groups:				
Bathtub, Lavatory and Water Closet–FM <sup>b</sup>	2.0	7.5	8.0	
Bathtub, Lavatory and Water Closet–FT <sup>c</sup>	2.0	3.5	4.0	
Shower Stall, Lavatory and Water Closet–FM	1.5	7.0	7.5	
Shower Stall, Lavatory and Water Closet–FT	1.5	3.0	3.5	

<sup>a</sup> For fixtures not listed, factors may be assumed by comparing the fixture to a listed fixture which uses water in similar quantities and at similar rates.

<sup>b</sup> FM means flushometer type. <sup>c</sup> FT means flush tank type.

SPS 382.40

Water Supply Fixture Units for Public Use Fixtures			Conversion of Water Supply Fixture Units			
	Water Supply Fixture Units		Water	to Gallons Per Minute Gallons per Minute		
Type of Fixture <sup>a</sup>		(wsfu)		Predominately Flush-	Predominately Flush	
		Cold	Total	Supply	ometer Type Water	Tank Type Water
Automatic Clothes Washer, Individual	2.0	2.0	3.0	Fixture Units	Urinals	Urinals
Automatic Clothes Washer, Large Capacity	b	b	b	1		1
Autopsy Table		2.0	3.0	2	_	2
Bathtub. With or Without Shower Head		2.0	3.0	3	_	3
Coffeemaker		0.5	0.5	4	10	4
Dishwasher, Commercial		b	b	5	15	4.5
Drink Dispenser		0.5	0.5	6	18	5
Drinking Fountain		0.25	0.25	7	21	6
Glass Filler		0.5	0.5	8	24	6.5
Health Care Fixtures:		0.0	0.0	9	26	7
Clinic sink	2.0	7.0	7.0	10	27	8
Exam/treatment sink	0.5	0.5	1.0	20	35	14
Sitz bath	1.5	1.5	2.0	30	40	20
Suzzon weshun	1.5	1.5	2.0	40	46	24
Surgeon washup	1.5	1.5	2.0	50	51	28
		2.0	2.0	60	54	32
$\frac{1}{2}$ diameter		3.0	3.0	70	58	35
<sup>3</sup> / <sub>4</sub> diameter		4.0	4.0	80	62	38
Icemaker		0.5	0.5	90	65	41
Lavatory	0.5	0.5	1.0	100	68	42
Shower, Per Head	2.0	2.0	3.0	120	73	48
Sinks:				140	78	53
Bar and Fountain	1.5	1.5	2.0	160	83	57
Barber and Shampoo	1.5	1.5	2.0	180	87	61
Cup		0.5	0.5	200	92	65
Flushing Rim		7.0	7.0	250	101	75
Kitchen and Food Preparation	2.0	2.0	3.0	300 400	110	85 105
Laboratory	1.0	1.0	15	400 500	142	105
Service sink	2.0	2.0	3.0	500	142	123
Urinal.	2.0	2.0	5.0	700	170	145
Synhon let		4.0	4.0	800	183	178
Weshdown		4.0	4.0	900	103	195
Wall Hydront Hat and Cold Mive		2.0	2.0	1000	208	208
wall Hydrant, Hot and Cold Mix:	2.0	2.0	2.0	1250	240	200
$\frac{1}{2}$ diameter	2.0	2.0	3.0	1500	240	240
<sup>3</sup> / <sub>4</sub> diameter	3.0	3.0	4.0	1750	294	294
Wash Fountain:				2000	321	321
Semicircular	1.5	1.5	2.0	2250	348	348
Circular	2.0	2.0	3.0	2500	375	375
Water Closet:				2750	402	402
Flushometer		6.5	6.5	3000	432	432
Gravity Type Flush Tank		3.0	3.0	4000	525	525
<sup>a</sup> For fixtures not listed, factors may be assumed by comparing the fixture to a listed fixture which uses water in similar quantities and at similar rates.				5000	593	593

Table 382.40-2 Water Supply Fixture Units for Public Use Fixtures

<sup>b</sup> For instances not instead, racions may be assumed by comparing the instance to a listed fixture which uses water in similar quantities and at similar rates. <sup>b</sup> Load factors in gallons per minute, gpm, based on manufacturer's requirements.

Note: Values not specified in the table may be calculated by interpolation.

Table 382.40-3