

DESIGN COORDINATION CHECKLIST

Project Name:	Project No	:
Drawing title,	Originator	:
with number and revision	Checker	:
	Reviewer	:

No.	Aspect Reviewed	Coordinated Yes No N/A		Remarks
1	Main electrical room has sufficient space for electrical and transformers (room & equipment drawn to scale) switchgear			
2	Each electrical room has sufficient space for panels and transformers (room and equipment drawn to scale)			
3	Housekeeping pads shown on architectural or structural			
4	Emergency generator room sized for largest generator model			
5	Electrical switchgear, transformers and panels have minimum required clearances			
6	Panel boards not in electrical rooms match architectural locations			
7	Location of equipment on electrical matches mechanical and plumbing			
8	Sufficient spare capacity provided at main switchgear, motor control centers and emergency generators			
9	Check location of vertical bus risers with location of structural beams			
10	Slab openings for bus risers match structural locations			
11	Does architectural have equipment that requires power?			
12	Power for architectural equipment matches architectural			
13	Power for mechanical equipment matches mechanical power requirements			
14	Power for plumbing equipment matches plumbing power requirements			
15	Location of light fixtures match architectural ceiling plan			



DESIGN COORDINATION CHECKLIST

Project Name:	Project No	:
Drawing title,	Originator	:
with number and revision	Checker	:
	Reviewer	:

No.	Aspect Reviewed	Coordinated Yes No N/A		Remarks
16	All wall mounted lights have mounting height shown			
17	All wall mounted lights are above or beyond door swings			
18	Verify emergency lighting provided where required			
19	All pendant (or chain) mounted lights have mounting height shown			
20	Disconnect switches provided for all mechanical, plumbing and elevator equipment			
21	Fire/life safety riser to show connection to fans and another mechanical/plumbing equipment required to be controlled			
22	Fire/life safety riser to show connection to elevator equipment		-	
23	Fire alarm control panel is connected to emergency power or has a battery pack			
24	Provide life/safety speakers in mechanical, electrical, and fan rooms			
25	Fire control provided at kitchen hood exhaust ducts			
26	Duct smoke detector quantity and location match mechanical			
27	Receptacles not located in glass walls, windows or behind equipment			
28	Floor mounted receptacles to be dimensioned from grid lines or face of walls.			
29	Floor mounted receptacles to match architectural locations			
30	Variable frequency drives required by mechanical or plumbing being supplied by electrical			
31	Tamper switch provided at site pressure indicating valves			



DESIGN COORDINATION CHECKLIST

Project Name:	Project No	:
Drawing title,	Originator	:
with number and revision	Checker	:
	Reviewer	:

No.	Aspect Reviewed	Coordinated Yes No N/A		Remarks
32	Telephone conduit provided from group controller to telephone room			
33	Additional disconnect switches at elevator machine rooms were required			
34	Conduit provided from elevator shafts to fire control room			
35	Power provided to each EMS panel			
36	Power to kitchen equipment is provided per the kitchen drawings			
37	Hanging transformer details shown on architectural			
38	Light switches not located in glass walls, windows or behind equipment			
39	Locate in plan site vaults, transformer pads and duct banks			
40	Locations of underground vaults, manholes and duct banks do not interfere with civil site utilities			
41	Location of site light <mark>fixtures matches civil and</mark> landscaping			
42	Light pole footing detail shown on electrical drawings			
43	Provide power for irrigation controllers			
44	All exterior lighting controlled by one-time clock or one photocell			
45	Exterior light fixtures to be located in plan and elevation			
46	Lights in fountains and pools must have junction boxes above the water level			
47	Provide lighting on emergency power between the building exits and the property line			
48	Each light fixture has a type noted			



DESIGN COORDINATION CHECKLIST

Project Name:	Project No	:
Drawing title,	Originator	:
with number and revision	Checker	:
	Reviewer	:

No.	Aspect Reviewed	ordina No	nted N/A	Remarks
49	Each fixture type has been coordinated with the ceiling type (gypsum board, T-bar. fine line)			
50	Sufficient lighting provided in elevator machine rooms			
51	Provide lights in mechanical enclosures and inside air handlers			
52	Provide emergency lighting in each elevator machine room			
53	Check visibility of each exit sign			
54	Provide a security riser if there is security in the project			
55	Where there is door security hardware has electrical provided a door elevation showing conduit and location of each security item?			
56	Halon system schematic provided			
57	Verify that mechanical is providing the fans, ducts and dampers required for halon			
58	A telecommunication riser diagram has been provided			
59	Provide emergency telephones in stairwells (high-rise)			
60	Provide fireman's phone jack in stairwells and elevator lobbies (high-rise)			